

U of So Cal						
ENGINEERING		TEAM SCORE				POINTS
		APPROACH	EQUALS	EXCEEDS	ECLIPSES	/100
CONTEST CRITERIA		0-60%	61-80%	81-90%	91-100%	
<b>A. FUNCTIONALITY</b>						
1	Do the systems function as intended?			X		
2	Does the HVAC system maintain indoor air quality via contaminant control, fresh air ventilation, or both?			X		
3	Does the HVAC system maintain uniform thermal comfort conditions via temperature control, humidity control, air movement, and a successful distribution system design?		X			
<b>B. EFFICIENCY</b>						
1	Relative to conventional systems, how much energy will the systems save over the course of an entire year?			X		
2	Do the HVAC and lighting controls facilitate a reduction in energy consumption during an entire year of operation?			X		
<b>C. INNOVATION</b>						
1	Were any unique approaches used to solve design challenges?			X		
2	Do the proposed innovations have true market potential?			X		
<b>D. RELIABILITY</b>						
1	How long are the systems expected to operate at a high level of performance?		X			
2	How much maintenance is required to keep them operating at a high level?			X		
<b>E. DOCUMENTATION</b>						
1	Did the drawings, construction specifications, energy analysis results and discussion, and audiovisual engineering presentation enable the jury to conduct a preliminary evaluation of the design prior to its arrival at the competition site?		X			
2	Did the drawings, construction specifications, energy analysis results and discussion, and audiovisual engineering presentation accurately reflect the constructed project as assembled on the competition site?		X			
<b>Total</b>						80.0
<b>PUBLIC COMMENTS</b>						
Nice large operable skylight encouraging natural ventilation combined with external solar screen, good climate responsive design. Well integrated HVAC. Solar thermal hot water was integrated with heat pump system.						