



MEP Calculations Volume 2

Penn State Solar Decathlon Team
MorningStar: Under.One.Sun
Penn State

Faculty Advisor: David Riley

August 7, 2007



Calculations

Table of Contents

Water Use Estimate	1
Mechanical Load Calculations	4
Radiant Floor Heating Calculations	5
Cooling Load (Heat Pump Sizing) Calculations	9
Electrical Calculations	14
Feeder Load Calculations	15
Conduit Sizing Calculations	16
Branch Circuit Length Calculations	17



Water Use Estimate

Water Use Estimate

Activity	gallons / use	# uses per day	# days of use	gallons used in contest	safety factor	Total Gallons	Water Type
Dishwasher	10	1	4	40	1.10	44.00	HOT
Washing Machine	25	1	2	50	1.10	55.00	HOT
Cooking (water vap.)	0.75	1	3	2.25	1.10	2.48	HOT
Shower Tests	15	2	5	150	1.20	180.00	HOT
HPWH Tank (WH-1)	38		filling only		1.00	38.00	Cold
Solar DHW HTX	1		filling only		1.50	1.50	Cold
20 Gal Heat Storage Tank	20		filling only		1.00	20.00	Cold
DHW Plumbing	2		filling only		1.50	3.00	Cold
Dry Cooler	2		filling only		1.50	3.00	Cold
Radiant Floor	20		filling only		1.50	30.00	Cold
Solar Heat Storage Tank	52		filling only		1.10	57.20	Cold
Solar Loop	4		filling only		1.10	4.40	Cold
Hydronic Plumbing	4		filling only		1.50	6.00	Cold
Heat Pump HTX	2		filling only		1.50	3.00	Cold
South Wall Milk Bottles	128		filling only		1.00	128.00	Cold
Plant Watering	50		1		1.00	500.00	Cold
Rain Garden	1225		filling only		1.00	1225.00	Cold

Total Gallons Needed - NO safety factor	1790
Total Gallons Needed w/ safety factor	2301
Overall Safety Factor	1.29


Yahoo! My Yahoo! Mail Make Y! your home page

Search:

Web Search

YAHOO! GROUPSWelcome, **psu_lewis**
[Sign Out, My Account]

Groups Home - Help



Life changes, why can't your structured settlement change with it?
Request a FREE quote to get cash now! [CLICK HERE](#) **J.G. WENTWORTH**
Advanced Funding

psu_lewis · psu_lewis@yahoo.com | Group Member - Edit Membership

[Start a Group](#) | [My Groups](#)**SD2007** · 2007 Solar Decathlon[Home](#)
[Messages](#)
[Post](#)
[Files](#)
[Photos](#)
[Links](#)
[Database](#)
[Polls](#)
[Members](#)
[Calendar](#)**Yahoo! Groups Tips**

Did you know...
Real people. Real stories.
See how Yahoo! Groups
impacts members
worldwide.

Yahoo! 360°

Share your life
through photos,
blogs, more.

Edit Record[Edit Record Help](#)**Edit Record**Team name: Quantity of water
required in U.S.
gallons: Number of filling
locations: Number of
removal locations: Will vegetation
grown on site be
eaten? (Y/N): Pre-water delivery
vegetation
watering source
(s): Post-water
delivery vegetation
watering source
(s): **SPONSOR RESULTS**

Online College Search

www.LearnAndBecome.com - 10 Questions to help you find the right online college for you.

Online University Information

www.CareerDegreeSource.com - Get your education online. Accredited programs and schools.

Take Control of Your Complexion

www.sheercover.com - 30-Day Intro Kit only \$29.95. Sheer Cover® Cosmetics by Leeza Gibbons.

Copyright © 2007 Yahoo! Inc. All rights reserved.
[Privacy Policy](#) - [Copyright/TP Policy](#) - [Terms of Service](#) - [Guidelines](#) - [Help](#)



Mechanical Load Calculations

Radiant Design Details

Project #: 1
Date: Feb 02, 2007
Prepared For: Penn State

Penn State University 104 Engineering Unit A University Park, PA 16802
Prepared By: Angela Lewis Phone: 7035057350 Email: ama259@psu.edu

Project Summary

Project #:	1
Project Name:	Morningstar PSU Solar D House
Location:	Washington DC
CloseDate:	
Engineer:	Angela Lewis
Design Data Location:	(User-Specified Location)
Outdoor Temperature:	3 °F
Wind Speed:	22 mph
Total Area:	625 ft²
Construction Quality:	Best
Rooms Requiring : Supplemental Heat	Living Room - Floorplan 1 Kitchen - Floorplan 1 Bathroom - Floorplan 1
Water Source 1 :	2.3 USGPM @ 3.4 ft(H2O) Head (incl S&R and device)
Total Loops:	6
Total Manifolds:	3
Total Zones:	3
Min. Tubing Required:	1,059 ft
RFH Glycol Level:	100% Water
Design Temp. Drop:	10 °F
Radiant Tubing Volume:	9.7 gallons(US)
Volume Water:	9.7 gallons(US)
Volume Glycol:	0 gallons(US)
Total Load:	16,023 Btu/hr
Total Radiant Load:	10,305 Btu/hr

Zone Design Summary

Zone 1

Area Served:	395 ft²	Rooms Served:	Living Room - Floorplan 1
Total Loops:	3		
Total Flowrate:	1.5 USGPM		
Maximum Head Loss:	2.4 ft(H2O)		

Zone 3

Area Served:	180 ft²	Rooms Served:	Kitchen - Floorplan 1
Total Loops:	2		
Total Flowrate:	0.7 USGPM		
Maximum Head Loss:	0.9 ft(H2O)		

Radiant Design Details

Project #: 1
Date: Feb 02, 2007
Prepared For: Penn State

Penn State University 104 Engineering Unit A University Park, PA 16802
Prepared By: Angela Lewis Phone: 7035057350 Email: ama259@psu.edu

Zone 4

Area Served: 50 ft²
Total Loops: 1
Total Flowrate: 0.1 USGPM
Maximum Head Loss: 0.1 ft(H₂O)

Rooms Served: Bathroom - Floorplan 1

Manifold And Water Temperature Summary

Water Source 1 (104.7 °F)

Area Served: 625 ft²
Total Manifolds: 3
Total Circuits: 6

Total Flowrate: 2.3 USGPM
Maximum Head Loss: 3.4 ft(H₂O)
Controls: Tempering Valve

Manifold	Zone Control	# Circuits	Flow Rate (USGPM)	Head Loss (ft(H ₂ O))	Max. Water Temp. (°F)	# Actuators
Manifold 1	Zone valves	3	1.5	2.4	105	0
Manifold 2	Zone valves	2	0.7	0.9	105	0
Manifold 3	Zone valves	1	0.1	0.1	105	0

Radiant Heating System Design

Living Room - Floorplan 1

Total Area: 395 ft²
Heated Area: 395 ft²
Total Heat Loss: 10,338 Btu/hr
Supplemental Heat: (2,800) Btu/hr
Total Radiant Load: 6,686 Btu/hr
Design Fluid Temp. Drop: 10 °F
Floor Unit Load: 16.9 Btu/hr/ft²

Living Room/Floor

#	Manifold	Length (ft)	Leader Length (ft)	Tube Spacing (in)	Flow Rate (USGPM)	Head Loss (ft(H ₂ O))	Valve Turns	Actuator
1	Manifold 1	218	10.0	8	0.5	2.4	4.0	No
2	Manifold 1	218	10.0	8	0.5	2.4	4.0	No
3	Manifold 1	218	10.0	8	0.5	2.4	4.0	No

Radiant Design Details

Project #: 1
Date: Feb 02, 2007
Prepared For: Penn State

Penn State University 104 Engineering Unit A University Park, PA 16802
Prepared By: Angela Lewis Phone: 7035057350 Email: ama259@psu.edu

Kitchen - Floorplan 1

Total Area: 180 ft²
Heated Area: 180 ft²
Total Heat Loss: 4,733 Btu/hr
Supplemental Heat: (1,275) Btu/hr
Total Radiant Load: 3,069 Btu/hr
Design Fluid Temp. Drop: 10 °F
Floor Unit Load: 17.1 Btu/hr/ft²

Kitchen/Floor

#	Manifold	Length (ft)	Leader Length (ft)	Tube Spacing (in)	Flow Rate (USGPM)	Head Loss (ft(H2O))	Valve Turns	Actuator
1	Manifold 2	155	10.0	8	0.3	0.9	4.0	No
2	Manifold 2	155	10.0	8	0.3	0.9	4.0	No

Bathroom - Floorplan 1

Total Area: 50 ft²
Heated Area: 50 ft²
Total Heat Loss: 952 Btu/hr
Supplemental Heat: (300) Btu/hr
Total Radiant Load: 550 Btu/hr
Design Fluid Temp. Drop: 10 °F
Floor Unit Load: 11 Btu/hr/ft²

Bathroom/Floor

#	Manifold	Length (ft)	Leader Length (ft)	Tube Spacing (in)	Flow Rate (USGPM)	Head Loss (ft(H2O))	Valve Turns	Actuator
1	Manifold 3	95	10.0	8	0.1	0.1	4.0	No

Radiant Panel Summary

Project #: 1
Date: Jul 07, 2007
 Prepared For: Penn State

Penn State University 104 Engineering Unit A University Park, PA 16802
 Prepared By: Angela Lewis Phone: 7035057350 Email: ama259@psu.edu

Total Area: 625 ft² Total Heat Load: 16,023 Btu/hr Total Flowrate: 2.3 USGPM Maximum Head Loss: 2.4 ft(H2O)

Floorplan 1

Room	Heating	Zone #	Heated Area	Unheated Area	Construction	Attachment Method	Tube Type	Tube Spacing	Ldr. Len	Loop Length	# Loops	Room Load per ft²	Surface Temp	Design Temp Drop	Flowrate (Total)	Head Loss	Fluid Temp Req.	Fluid Temp Supplied
Living Room	Floor	1	395	0	Suspended / Joist 16"	Joist Trak Plates	hePEX 1/2"	8	10	218	3	16.9	73.5	10	1.5	2.4	104	105
Kitchen	Floor	3	180	0	Suspended / Joist 16"	Joist Trak Plates	hePEX 1/2"	8	10	155	2	17.1	73.5	10	0.69	0.88	105	105
Bathroom	Floor	4	50	0	Suspended / Joist 16"	Joist Trak Plates	hePEX 1/2"	8	10	95	1	11	70.5	10	0.13	0.09	94	105

Area = ft²; Spacing = in; Length = ft; Unit Heat = Btu/hr/ft²; Temperature = °F; Flow Rate = USGPM; Head Loss = ft(H2O)

System Checksums

By Southland Industries

Heat Pump

Incremental Heat Pump

COOLING COIL PEAK										CLG SPACE PEAK										HEATING COIL PEAK									
Peaked at Time: Outside Air:					Mo/Hr: OADBWB/HR: Sum of Peaks					Mo/Hr: Sum of OADB: Peaks					Mo/Hr: Heating Design OADB: 42														
Space Sens. + Lat. Btu/h					Plenum Sens. + Lat. Btu/h					Net Percent Total Of Total Btu/h					Space Percent Sensible Of Total Btu/h					Space Peak Space Sens Btu/h					Coil Peak Percent Tot Sens Of Total Btu/h				
Envelope Loads					Envelope Loads					Envelope Loads					Envelope Loads					Envelope Loads					Envelope Loads				
Skylite Solar					Skylite Solar					Skylite Solar					Skylite Solar					Skylite Solar					Skylite Solar				
Roof Cond					Roof Cond					Roof Cond					Roof Cond					Roof Cond					Roof Cond				
Glass Solar					Glass Solar					Glass Solar					Glass Solar					Glass Solar					Glass Solar				
Wall Cond					Wall Cond					Wall Cond					Wall Cond					Wall Cond					Wall Cond				
Partition					Partition					Partition					Partition					Partition					Partition				
Exposed Floor					Exposed Floor					Exposed Floor					Exposed Floor					Exposed Floor					Exposed Floor				
Infiltration					Infiltration					Infiltration					Infiltration					Infiltration					Infiltration				
Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>				
Internal Loads					Internal Loads					Internal Loads					Internal Loads					Internal Loads					Internal Loads				
Lights					Lights					Lights					Lights					Lights					Lights				
People					People					People					People					People					People				
Misc					Misc					Misc					Misc					Misc					Misc				
Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>					Sub Total ==>				
Ceiling Load					Ceiling Load					Ceiling Load					Ceiling Load					Ceiling Load					Ceiling Load				
Ventilation Load					Ventilation Load					Ventilation Load					Ventilation Load					Ventilation Load					Ventilation Load				
Dehumid. Ov Sizing					Dehumid. Ov Sizing					Dehumid. Ov Sizing					Dehumid. Ov Sizing					Dehumid. Ov Sizing					Dehumid. Ov Sizing				
Ov/Undr Sizing					Ov/Undr Sizing					Ov/Undr Sizing					Ov/Undr Sizing					Ov/Undr Sizing					Ov/Undr Sizing				
Exhaust Heat					Exhaust Heat					Exhaust Heat					Exhaust Heat					Exhaust Heat					Exhaust Heat				
Sup. Fan Heat					Sup. Fan Heat					Sup. Fan Heat					Sup. Fan Heat					Sup. Fan Heat					Sup. Fan Heat				
Ret. Fan Heat					Ret. Fan Heat					Ret. Fan Heat					Ret. Fan Heat					Ret. Fan Heat					Ret. Fan Heat				
Duct Heat Pkup					Duct Heat Pkup					Duct Heat Pkup					Duct Heat Pkup					Duct Heat Pkup					Duct Heat Pkup				
Reheat at Design					Reheat at Design					Reheat at Design					Reheat at Design					Reheat at Design					Reheat at Design				
Grand Total ==>					Grand Total ==>					Grand Total ==>					Grand Total ==>					Grand Total ==>					Grand Total ==>				

COOLING COIL SELECTION										HEATING COIL SELECTION																			
Total Capacity ton					Sens Cap. MBh					Coil Airflow cfm					Capacity MBh					Coil Airflow cfm					Lvg °F				
Main Clg					Main Clg					Main Clg					Main Clg					Main Clg					Main Clg				
Aux Clg					Aux Clg					Aux Clg					Aux Clg					Aux Clg					Aux Clg				
Opt Vent					Opt Vent					Opt Vent					Opt Vent					Opt Vent					Opt Vent				
Total					Total					Total					Total					Total					Total				

ENGINEERING CKS									
% OA					Heating				
cfm/ft²					0.0				
cfm/ton					0.96				
ft³/ton					545.20				
Btu/hr-ft²					566.40				
No. People					21.19				
					-54.72				
					2				

AREAS									
Gross Total					Glass ft² (%)				
Floor					651				
Part					530				
ExFlr					651				
Roof					137				
Wall					1,007				
					9				
					349				
					7				
					35				

Room Checksums

By Southland Industries

Bedroom

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air: OADB/WB/HR: 68 / 57 / 52				Mo/Hr: 10 / 14 OADB: 68				Mo/Hr: Heating Design OADB: 42				SADB Cooling Heating			
Sens. + Lat. Btu/h	Space Btu/h	Plenum Btu/h	Net Percent Total Of Total Btu/h	Space Sensible Btu/h	Percent Of Total (%)	Space Sens Btu/h	Percent Of Total (%)	Space Peak Btu/h	Coil Peak Btu/h	Coil Peak Percent Of Total (%)	Envelope Loads	SADB	Cooling	Heating	
Envelope Loads												Plenum	55.0	125.0	
Skylite Solar	0	0	0	0	0	0	0	0	0	0	Skylite Solar	Return	74.0	74.0	
Skylite Cond	0	0	0	0	0	0	0	0	0	0	Skylite Cond	Ret/OA	74.0	74.0	
Roof Cond	0	0	0	0	0	0	0	0	0	0	Roof Cond	Fn MtrTD	0.1	0.0	
Glass Solar	1,684	0	1,684	1,684	87	1,684	87	-984	-984	19	Glass Solar	Fn BldTD	0.2	0.0	
Glass Cond	-263	0	-263	-263	-14	-263	-14	-263	-263	5	Glass Cond	Fn Frict	0.5	0.0	
Wall Cond	130	0	130	130	7	130	7	-211	-211	4	Wall Cond				
Partition	-95	0	-95	-95	-5	-95	-5	-220	-220	4	Partition				
Exposed Floor	-128	0	-128	-128	-7	-128	-7	-245	-245	5	Exposed Floor				
Infiltration	-42	0	-42	-42	-2	-42	-2	-1,924	-1,924	37	Infiltration				
Sub Total ==>	1,286	0	1,286	1,280	66	1,280	66	-1,924	-1,924		Sub Total ==>				
Internal Loads											Internal Loads				
Lights	657	0	657	657	34	657	34	0	0	0	Lights				
People	0	0	0	0	0	0	0	0	0	0	People				
Misc	0	0	0	0	0	0	0	0	0	0	Misc				
Sub Total ==>	657	0	657	657	34	657	34	0	0	0	Sub Total ==>				
Ceiling Load	0	0	0	0	0	0	0	0	0	0	Ceiling Load				
Ventilation Load	0	0	0	0	0	0	0	0	0	0	Ventilation Load				
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	Dehumid. Ov Sizing				
Ov/Undr Sizing	0	0	0	0	0	0	0	-3,274	-3,274	63	Ov/Undr Sizing				
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	Exhaust Heat				
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	Sup. Fan Heat				
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	Ret. Fan Heat				
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	Duct Heat Pkup				
Reheat at Design	0	0	0	0	0	0	0	0	0	0	Reheat at Design				
Grand Total ==>	1,943	0	1,943	1,937	100.00	1,937	100.00	-5,198	-5,198	100.00	Grand Total ==>				

AIRFLOWS

Vent	0	Cooling	0	Heating	0
Infil	7		7		7
Supply	91		91		91
MinStop/Rh	0		0		0
Return	98		98		98
Exhaust	7		7		7
Rm Exh	0		0		0
Auxil	0		0		0

ENGINEERING CKS

% OA	0.0	Cooling	0.0	Heating	0.0
cfm/ft²	0.67		0.67		0.67
cfm/ton	564.83		564.83		564.83
ft³/ton	849.36		849.36		849.36
Btu/hr-ft²	14.13		14.13		-37.81
No. People	0		0		0

HEATING COIL SELECTION

Capacity	Coil	Airflow	Ent	Lvg
MBh		cfm	°F	°F
-5.2	Main Htg	91	74.0	125.0
0.0	Aux Htg	0	0.0	0.0
0.0	Preheat	0	0.0	0.0
0.0	Humidif	0	0.0	0.0
0.0	Opt Vent	0	0.0	0.0
-5.2	Total			

AREAS

Gross Total	Glass	ft²	(%)
138	Floor		
143	Part		
138	ExFlr		
0	Roof		
266	Wall		
60			23

COOLING COIL SELECTION

Total Capacity	Sens Cap.	Coil	Airflow	Enter	DBWB/HR	Leave	DBWB/HR
ton	MBh		cfm	°F	°F	°F	°F
0.2	1.9	1.9	91	74.0	59.1	51.3	51.3
0.0	0.0	0.0	0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0	0.0	0.0	0.0	0.0
0.2	1.9						

Room Checksums

By Southland Industries

Breezeway

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			
Peaked at Time: Outside Air: OADB/WB/HR: 68 / 57 / 50				Mo/Hr: 10 / 16 OADB: 68				Mo/Hr: Heating Design OADB: 42			
Envelope Loads		Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Percent Total Of Total Btu/h	Space Sensible Of Total Btu/h	Space Percent Sensible Of Total (%)	Envelope Loads	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	
Skyliite Solar	0	0	0	0	0	0	Skyliite Solar	0	0	0	
Skyliite Cond	0	0	0	0	0	0	Skyliite Cond	0	0	0	
Roof Cond	0	0	0	0	0	0	Roof Cond	0	0	0	
Glass Solar	1,673	0	1,673	150	1,673	150	Glass Solar	-2,418	-2,418	81	
Glass Cond	-576	0	-576	-52	-576	-52	Glass Cond	0	0	0	
Wall Cond	22	0	22	2	22	2	Wall Cond	-67	-67	2	
Partition	-54	0	-54	-5	-54	-5	Partition	-168	-168	6	
Exposed Floor	-106	0	-106	-10	-106	-10	Exposed Floor	-182	-182	6	
Infiltration	-35	0	-35	-3	-32	-3	Infiltration	-163	-163	5	
Sub Total ==>	924	0	924	83	927	83	Sub Total ==>	-2,998	-2,998	100	
Internal Loads				Internal Loads							
Lights	0	0	0	0	0	0	Lights	0	0	0	
People	0	0	0	0	0	0	People	0	0	0	
Misc	0	0	0	0	0	0	Misc	0	0	0	
Sub Total ==>	0	0	0	0	0	0	Sub Total ==>	0	0	0	
Ceiling Load				Ceiling Load							
Ventilation Load	0	0	0	0	0	0	Ventilation Load	0	0	0	
Dehumid. Ov Sizing	0	0	0	0	0	0					
Ov/Undr Sizing	190	0	190	17	190	17	Ov/Undr Sizing	0	0	0	
Exhaust Heat	0	0	0	0	0	0	Exhaust Heat	0	0	0	
Sup. Fan Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0	0	
Ret. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	0	0	
Duct Heat PkUp	0	0	0	0	0	0	Additional Reheat	0	0	0	
Reheat at Design	0	0	0	0	0	0	System Plenum Heat	0	0	0	
Grand Total ==>	1,114	0	1,114	100.00	1,117	100.00	Grand Total ==>	-2,998	-2,998	100.00	

TEMPERATURES			
SADB	Cooling	Heating	
Plenum	55.0	125.0	
Return	74.0	74.0	
Ret/OA	74.0	74.0	
Fn MtrTD	0.1	0.0	
Fn BldTD	0.2	0.0	
Fn Frict	0.5	0.0	

AIRFLOWS			
Vent	Cooling	Heating	
Infil	0	0	
Supply	53	53	
MinStop/Rh	0	0	
Return	57	57	
Exhaust	5	5	
Rm Exh	0	0	
Auxil	0	0	

ENGINEERING CKS			
% OA	Cooling	Heating	
cfm/ft²	0.0	0.0	
cfm/ton	0.46	0.46	
ft³/ton	566.57		
Btu/hr-ft²	1,224.62		
No. People	9.80	-26.30	

HEATING COIL SELECTION			
Capacity	Coil Airflow	Ent	Lvg
MBh	cfm	°F	°F
-3.0	53	74.0	125.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.

TEMPERATURES

SADB	Cooling	Heating
Plenum	55.0	125.0
Return	74.0	74.0
Ret/OA	74.0	74.0
Fn MtrTD	0.1	0.0
Fn BldTD	0.2	0.0
Fn Frict	0.5	0.0

AIRFLOWS

Vent	Cooling	Heating
Infil	0	0
Supply	53	53
MinStop/Rh	0	0
Return	57	57
Exhaust	5	5
Rm Exh	0	0
Auxil	0	0

ENGINEERING CKS

% OA	Cooling	Heating
cfm/ft²	0.0	0.0
cfm/ton	0.46	0.46
ft²/ton	566.57	566.57
Btu/hr-ft²	1,224.62	1,224.62
No. People	9.80	-26.30

HEATING COIL SELECTION

Capacity	Coil	Airflow	Ent	Lvg
MBh		cfm	°F	°F
Main Htg	-3.0	53	74.0	125.0
Aux Htg	0.0	0	0.0	0.0
Preheat	0.0	0	0.0	0.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-3.0			

AREAS

Gross Total	Glass
ft²	(%)
Floor	114
Part	114
ExFlr	114
Roof	0
Wall	200
	148
	74

COOLING COIL SELECTION

Total Capacity	Sens Cap.	Coil Airflow	Enter DBWB/HR	Leave DBWB/HR
ton	MBh	cfm	°F	°F
Main Clg	0.1	1.1	53	54.2
Aux Clg	0.0	0.0	0	0.0
Opt Vent	0.0	0.0	0	0.0
Total	0.1	1.1		

Room Checksums

By Southland Industries

Dining/Living

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			
Peaked at Time: Outside Air: OADB/WB/HR: 68 / 57 / 52				Mo/Hr: 10 / 15 OADB: 68				Mo/Hr: Heating Design OADB: 42			
Envelope Loads		Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Total (%)	Space Sensible Btu/h	Percent Total (%)	Envelope Loads	Space Peak Btu/h	Coil Peak Tot Btu/h	Percent Total (%)
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0
Roof Cond	0	0	0	0	0	0	0	Roof Cond	0	0	0
Glass Solar	4,508	0	0	4,508	77	4,508	77	Glass Solar	0	0	0
Glass Cond	-489	0	0	-489	-8	-489	-8	Glass Cond	-2,030	-2,030	13
Wall Cond	143	0	0	143	2	143	2	Wall Cond	-277	-277	2
Partition	-153	0	0	-153	-2	-153	-2	Partition	-403	-403	3
Exposed Floor	-246	0	0	-246	-4	-246	-4	Exposed Floor	-420	-420	3
Infiltration	-74	0	0	-74	-1	-85	-1	Infiltration	-468	-468	3
Sub Total ==>	3,690	0	0	3,690	58	3,678	63	Sub Total ==>	-3,598	-3,598	23
Internal Loads				1,254	20	1,254	21	Internal Loads	0	0	0
Lights	1,000	0	0	1,000	16	500	9	Lights	0	0	0
People	448	0	0	448	7	448	8	People	0	0	0
Misc	2,702	0	0	2,702	42	2,202	37	Misc	0	0	0
Sub Total ==>	2,702	0	0	2,702	42	2,202	37	Sub Total ==>	0	0	0
Ceiling Load				0	0	0	0	Ceiling Load	0	0	0
Ventilation Load	0	0	0	0	0	0	0	Ventilation Load	0	0	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	-12,186	-12,186	77
Exhaust Heat	0	0	0	0	0	0	0	Exhaust Heat	0	0	0
Sup. Fan Heat	0	0	0	0	0	0	0	OA Preheat Diff.	0	0	0
Ret. Fan Heat	0	0	0	0	0	0	0	RA Preheat Diff.	0	0	0
Duct Heat PkUp	0	0	0	0	0	0	0	Additional Reheat	0	0	0
Reheat at Design	0	0	0	0	0	0	0	System Plenum Heat	0	0	0
Grand Total ==>	6,392	0	0	6,392	100.00	5,881	100.00	Grand Total ==>	-15,785	-15,785	100.00
COOLING COIL SELECTION				HEATING COIL SELECTION							
Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter DBWB/HR °F	Leave DBWB/HR °F	Gross Total ft²	Glass ft² (%)	Capacity Coil Airflow cfm				
Main Clg	0.5	6.4	278	74.0	263	0	-15.8				
Aux Clg	0.0	0.0	0	50.8	273	0	0.0				
Opt Vent	0.0	0.0	0	0.0	263	0	0.0				
Total	0.5	6.4	0	0.0	341	124 36	0.0				

Room Checksums

By Southland Industries

Kitchen

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air: OADB/WB/HR: 68 / 57 / 52				Mo/Hr: 10 / 15 OADB: 68				Mo/Hr: Heating Design OADB: 42				SADB Cooling Heating 55.0 125.0			
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Space Sensible Btu/h	Percent Of Total (%)	Envelope Loads	Space Sensible Btu/h	Space Peak Btu/h	Coil Peak Tot Btu/h	Percent Of Total (%)		SADB	Cooling	Heating	
Skyline Solar	296	0	296	296	7	Skyline Solar	296	0	0	0		Plenum	55.0	125.0	
Skyline Cond	-35	0	-35	-35	-1	Skyline Cond	-35	-147	-147	1		Return	74.0	74.0	
Roof Cond	43	0	43	43	1	Roof Cond	43	-66	-66	1		Ret/OA	74.0	74.0	
Glass Solar	44	0	44	44	1	Glass Solar	44	0	0	0		Fn MtrTD	0.1	0.0	
Glass Cond	-31	0	-31	-31	-1	Glass Cond	-31	-131	-131	1		Fn BldTD	0.2	0.0	
Wall Cond	-15	0	-15	-15	0	Wall Cond	-15	-108	-108	1		Fn Frict	0.5	0.0	
Partition	0	0	0	0	0	Partition	0	0	0	0					
Exposed Floor	-62	0	-62	-62	-2	Exposed Floor	-62	-118	-118	1					
Infiltration	-21	0	-21	-21	-1	Infiltration	-21	-131	-131	1					
Sub Total ==>	219	0	219	216	5	Sub Total ==>	216	-701	-701	6					
Internal Loads	440	0	440	440	11	Internal Loads	440	0	0	0					
Lights	0	0	0	0	0	Lights	0	0	0	0					
People	3,413	0	3,413	3,413	84	People	3,413	0	0	0					
Misc	3,853	0	3,853	3,853	95	Misc	3,853	0	0	0					
Sub Total ==>	440	0	440	440	11	Sub Total ==>	440	0	0	0					
Ceiling Load	0	0	0	0	0	Ceiling Load	0	0	0	0					
Ventilation Load	0	0	0	0	0	Ventilation Load	0	0	0	0					
Dehumid. Ov Sizing	0	0	0	0	0	Dehumid. Ov Sizing	0	0	0	0					
Ov/Undr Sizing	0	0	0	0	0	Ov/Undr Sizing	0	-10,219	-10,219	94					
Exhaust Heat	0	0	0	0	0	Exhaust Heat	0	0	0	0					
Sup. Fan Heat	0	0	0	0	0	OA Preheat Diff.	0	0	0	0					
Ret. Fan Heat	0	0	0	0	0	RA Preheat Diff.	0	0	0	0					
Duct Heat PkUp	0	0	0	0	0	Additional Reheat	0	0	0	0					
Reheat at Design	0	0	0	0	0	System Plenum Heat	0	0	0	0					
Grand Total ==>	4,071	0	4,071	4,068	100.00	Grand Total ==>	4,068	-10,920	-10,920	100.00					

AIRFLOWS

	Cooling	Heating
Vent	0	0
Infil	4	4
Supply	192	192
MinStop/Rh	0	0
Return	196	196
Exhaust	4	4
Rm Exh	0	0
Auxil	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	0.0	0.0
cfm/ft²	2.09	2.09
cfm/ton	566.13	
ft³/ton	271.17	
Btu/hr-ft²	44.25	-118.69
No. People	0	

COOLING COIL SELECTION

Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter °F	Leave DBWB/HR °F	gr/lb
0.3	4.1	192	74.0	59.1	51.3
0.0	0.0	0	0.0	0.0	0.0
0.0	0.0	0	0.0	0.0	0.0
0.3	4.1				

AREAS

Gross Total	Glass ft² (%)
Floor	92
Part	0
ExFlr	92
Roof	92
Wall	9

HEATING COIL SELECTION

Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
-10.9	192	74.0	125.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
-10.9			

Project Name: Solar House

Dataset Name: Y:\PSU Solar Decathlon\SD Nov 21 Southland\Trace Load\SolarD model for DavePeters.trc



Electrical Calculations

Feeder load	VA	DF	NEC Code	Demand Load
Lighting / General Receptacles (3VA/s.f.) (3VA/s.f. x 800s.f. = 2400VA)	2400	100%	220.82(B)	2400
Small Appliance circuit loads	3000	100%	220.82(B)	3000
Washer	1500	100%	220.82(B)	1500
Car Charger	1500	100%	220.82(B)	1500
Refrigerator	1800	100%	220.82(B)	1800
Dishwasher	875	100%	220.82(B)	875
Microhood	1500	100%	220.82(B)	1500
Dryer	5600	100%	220.82(B)	5600
Cooktop	7400	100%	220.82(B)	7400
AFC-1	667	100%	220.82(B)	667
P-1	1656	100%	220.82(B)	1656
ERV-1	150	100%	220.82(B)	150
EF-1	150	100%	220.82(B)	150
P-2 THRU P-6	30	100%	220.82(B)	30
Total				28228
1st 10000 VA at 100%				10000
Rest at 40%				7291.2
HPWH-1	1610	100%	220.82(C)(3)	1610
WH-1	6000	100%	220.82(C)(3)	6000
HP-1	4186	100%	220.82(C)(3)	4186
RH-1	4992	100%	220.82(C)(3)	4992
Total (VA)				34079.2
Total Demand Amps				141.9966667

CONDUIT SIZING FOR TYPICAL FEEDERS
2#12, #12(G), 1/2"C.
2#10, #10(G), 3/4"C.
2#8, #10(G), 3/4"C.
2#2/0, #4(G), 2"C.
3#1/0, #4(G), 2"C.

BRANCH CIRCUIT LENGTHS

Load Description: **Typical Branch Circuit # 12s**

Max Length (L):	63
Wire Size :	12
Load amps (I):	16
Voltage:	120
Connection Type:	4
# Parallel Sets:	1
Conduit Type:	N
Power Factor	0.90

Circuit Amp Ft.:	1,008
Table Value:	30.00
Multiplier:	1.18
Power Factor Index:	4

VD = 3.568 Volts, or 2.97 Percent

Load Description: **Typical Branch Circuit #10s**

Max Length (L):	67
Wire Size :	10
Load amps (I):	24
Voltage:	120
Connection Type:	4
# Parallel Sets:	1
Conduit Type:	N
Power Factor	0.90

Circuit Amp Ft.:	1,608
Table Value:	19.00
Multiplier:	1.18
Power Factor Index:	4

VD = 3.605 Volts, or 3.00 Percent

Load Description: **Typical Branch Circuit #8s**

Length (L):	150
Wire Size :	8
Load amps (I):	32
Voltage:	240
Connection Type:	4
# Parallel Sets:	1
Conduit Type:	N
Power Factor	0.90

Circuit Amp Ft.:	4,800
Table Value:	12.00
Multiplier:	1.18
Power Factor Index:	4

VD = 6.797 Volts, or 2.83 Percent

Voltage Drop Notes:

Power Factor Index	
0.70	2
0.80	3
0.90	4
0.95	5
1.00	6

Intermediate Data Results Do not enter data here

Final Result Data, Do not enter data here.

Cells for input of data

LOAD CONNECTION

1	Balanced 3 Phase line-to-line (Delta Connected)	no multiplier	1.00
2	Balanced line-to-neutral load (Wye Connected)	multiply by	0.58
3	Balanced line-to-neutral load (Single Phase 3W)	multiply by	0.58
4	Any 2 wire load	multiply by	1.18